

## JOB INFORMATION

**Reference / Job#:** 5714  
**Installation address:** 436C Thames Street, Morrinsville, 3300

## CUSTOMER INFORMATION

**Name:** Tarrant, TJ & DM      **Email:** t.tarrant0@xtra.co.nz      **Phone:** 07 889 3454  
**Postal address:** 450B Thames Street, Morrinsville, 3300      **Mobile:** 027 568 5165

## GASFITTER INFORMATION

**Name:** Anthony Wright      **Registration:** 10847  
**Company Name:** Wright Plumbing & Gas (Morrinsville) Ltd T/As Laser Plumbing Morrinsville      **Phone:** 0274888571  
**Email:** morrinsville@laserplumbing.co.nz

## WORK DETAILS

**Date Started:** 27/05/2022      **Date Completed:** 27/05/2022      **ICP:**  
**Applies to:** Whole Installation

### DESCRIPTION OF WORK DONE

ASSESS POSSIBLE GAS LEAK.  
 FOUND PIGTAIL IS LEAKING.  
 REPLACE 2 X GAS PIGTAILS.  
 DO BUBBLE TEST AND GAS PIPEWORK TEST.  
 ALL OKAY.

## GAS SAFETY CERTIFICATE

*I certify that the work described in this Gas Safety Certificate, and the installation or part installation, is connected to a gas supply and is safe to use.*

**Name:** Anthony Wright      **Registration:** 10847  
**Issue Date:** 17/06/2022      **Connection Date:** 27/05/2022  
**Certifier Signature:**




*This Gas Safety Certificate confirms that the gasfitting work complies with the building code for the purposes of Section 19(1)(e) Version 1.01 of the Building Act 2004.*

***This is an important document and should be retained for a minimum of seven years.***