



Compliance and Electrical Safety Certificate

This form has been issued by the Electrical Workers Registration Board



Safety • Competency

Unique ID: 8AR

This form has been designed to be used by licensed electrical workers to certify low voltage installations or part installations that comply with Part 2 of AS/NZS 3000 and are safe to be connected to a 230/400 volt multiple earth neutral (MEN) system of electrical supply.

(1) Location of Installation

Address: 8 ARAPITO ROAD, TITIRANGI - AUCKLAND

(2) Customer Information

Name: MARTIN BABER
 Postal Address: 8 ARAPITO ROAD, TITIRANGI - AUCKLAND
 Phone and Email: Martin.baber001@gmail.com

(3) Electrical Worker Information

Name: RYAN GILLARD Registration/Practising Licence Number: E 243578
 Organisation: ALLWORKZ ELECTRICAL LIMITED Telephone Number: 021519225
 Email: RYAN@ALLWORKZELECTRICAL.CO.NZ
 Name of person(s) being supervised: C. BROWN

(4) Work Details

The work is (circle): additions | alterations | new work
 The prescribed electrical work is: High Risk | General | Low Risk | The homeowner has undertaken part of the electrical installation work.

Indicate the number of each item

Installed or altered:

Number of lighting outlets:	<u>INSTALLED NEW SLUB</u>	Other Work?	Tick (✓) if work includes:
Number of socket outlets:	<u>MAINS + INCOMINGS</u>		<input checked="" type="radio"/> Mains
Number of ranges:	<u>MAINS FROM POLE</u>		<input checked="" type="radio"/> MEN switchboard closest to point of supply
Number of water heaters:	<u>INSTALLED NEW EARTHINGS</u>		<input type="radio"/> Main Earthing System
			<input type="radio"/> Electric Lines

(5) Certification of Work

I certify that the completed prescribed electrical work to which this certificate applies, has been done lawfully and safely and the information in the certificate is correct in that the installation, or part of the installation:

- has been installed in accordance with a certified design
- has an earthing system that is correctly rated
- contains fittings which are safe to connect to a power supply
- relies on supplier's Declaration of Conformity (attach or reference¹)
- relies on manufacturer's instructions (attach or reference¹)
- has been satisfactorily tested in accordance with Electricity (Safety) Regulations 2010
- is safe to connect

Electronic reference: [Signature]
 Electrical Worker's Signature: [Signature] Date: 3 JUN 2019

Test Results:		
	Electrical Worker	Inspector
Polarity (independent earth):		
Insulation resistance:	<u>2</u>	
Earth continuity:	<u>0.05 Ω M/KAEM</u>	
Bonding:	<u>20.5 Ω</u>	
Other (specify):	<u>R10</u>	

1. If it is impractical to attach a copy of a particular manufacturer's instructions, or of any certified design or supplier declarations of conformity, provide a reference to where the documents can be found, in a readily accessible format, through electronic means.

(6) Electrical Safety Certificate

I certify that the installation, or part of the installation, to which the Electrical Safety Certificate applies is connected to a power supply and is safe to use

Name: Ryan Gillard Registration/Practising Licence Number: E 243578
 Signature: [Signature] Date: 3 JUN 2019
 (if certifier is different from electrical worker)