



23 June 2020

Eves Real Estate
96 Walton Street
Whangarei 0110

Attention: Brett Sawyers

Report on Asbestos Analysis

Sampled by: Client
Date Received: 23 June 2020
Analysed by: Param Singh
Job No. : 0664/20 b
Client reference: 4 Wessex Place, Tikipunga
Location/Description: 4 Wessex Place, Tikipunga

Method: AS 4964 (2004) – Method for the Qualitative Identification of Asbestos in Bulk Samples and in-house Method 1.

The following samples were examined using Low Powered Stereomicroscopy followed by Polarised Light Microscopy' including Dispersion Staining Techniques.

Results only apply to the samples as received.

Sample No.	Description	Sample Size	Result
1803	House Veneer	26 g	Asbestos NOT detected

Yours Faithfully

R. N. (Bob) Mumford NZCS, Dip SM, MMgt (OSH).
Asbestos Analyst



NOTE:

1. This report must not be altered or reproduced except in full.
2. All analysis performed at the HealthSafe Field Laboratory located at 13 Tarewa Rd, Whangarei